

Efectis Nederland BV P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2018

Classification no. 2021-Efectis-R000777

Avery Dennison Materials Europe BV Sponsor

> Willem Einthovenstraat 11 2342 BH OEGSTGEEST

The Netherlands

Product name Avery Dennison MPI 3026 Matt high opacity

version (HOP)

Prepared by Efectis Nederland BV

Notified body no. 1234

Author(s) G. van der Lee M.Sc.

> B.R. Knottnerus B.Sc. A.H.L.M. Zwinkels B.Sc.

Project number ENL-21-000331

Date of issue August 2021

Number of pages 5

All rights reserved.

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland BV. Submitting the report for inspection to parties who have a direct interest is permitted.





Efectis Nederland BV 2021-Efectis-R000777 August 2021 Avery Dennison Materials Europe BV

CLASSIFICATION

INTRODUCTION

This classification report defines the classification assigned to **Avery Dennison MPI 3026 Matt high opacity version (HOP)** in accordance with the procedures given in EN 13501-1:2018.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, **Avery Dennison MPI 3026 Matt high opacity version (HOP)**, will be used on various super wide format printers.

2.2 MANUFACTURER

Avery Dennison Materials Europe BV Willem Einthovenstraat 11 2342 BH Oegstgeest The Netherlands

2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:

Face film: 95 μm, 125 g/m²;

monomeric calendered vinyl; Color: Opaque white matt film.

Adhesive: 25 μm, 23 g/m², permanent, clear, acrylic based;

Backing paper: clay coated kraft paper, 125 g/m².

The product has a total thickness of approx. 115 μm and a mass per unit area of approx.148 g/m².

More information on the product is available in the test report 2021-Efectis-R000775.

3. STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 APPLICABLE (PRODUCT) STANDARDS

EN ISO 11925-2:2020	Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test		
EN 13823:2020	Reaction to fire tests for building products - Building products, excluding floorings exposed to the thermal attack by a single burning item		
EN 13238:2010	Reaction to fire tests for building products - Conditioning procedures and general rules for selection of substrates		
EN 13501-1:2018	Fire classification of construction products and building elements Part 1: Classification using data from reaction to fire tests		





3.2 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Materials Europe BV THE NETHERLANDS	2021-Efectis-R000775 2021-Efectis-R000774	EN ISO 11925-2:2020 EN 13823:2020

3.3 TEST RESULTS

		tests par	Results	
Test method and test number	Parameter		Continuous parameter – maximum	Compliance with parameters
EN ISO 11925-2				
Surface flame	Fs ≤150 mm	6 25	25	-
impingement	Ignition of filter paper		-	Compliant
Edge flame Impingement	Fs ≤150 mm	6	25	-
	Ignition of filter paper		-	Compliant

	Parameter		No. tests	Results	
Test method and test number				Continuous parameter – mean (m)	Compliance with parameters
EN 13823					
	FIGRA _{0.2MJ}	[W/s]		46	-
	FIGRA _{0.4MJ}	[W/s]		9	-
	THR _{600s}	[MJ]		0.9	-
	LFS < edge			-	Compliant
	SMOGRA	[m ² /s ²]	3	11.4	-
	TSP _{600s}	[m ²]		42	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			- -	Compliant Compliant

CLASSIFICATION

3.4 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products					
Classification crit	Classification criteria				
Class Test method(s)	В	С	D		
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.				
EN 13823		FIGRA _{0.4 MJ} ≤ 250 W/s LFS < edge of specimen THR _{600s} ≤ 15 MJ	FIGRA _{0.4 MJ} ≤ 750 W/s		
Additional classification					
Smoke production	s1 = SMOGRA \leq 30 m ² /s ² and TSP _{600s} \leq 50 m ² ; s2 = SMOGRA \leq 180 m ² /s ² and TSP _{600s} \leq 200 m ² ; s3 = not s1 or s2				
Flaming Droplets/particles	 d0 = no flaming droplets/ particles in EN 13823 within 600 s; d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; d2 = not d0 or d1. 				

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2018.

4.2 CLASSIFICATION

The product, **Avery Dennison MPI 3026 Matt high opacity version (HOP)**, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

٩ſ

Reaction to fire classification: B - s1, d0



Efectis Nederland BV 2021-Efectis-R000777 August 2021 Avery Dennison Materials Europe BV

CLASSIFICATION

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness 115 µm

Surface density 148 g/m²

Other properties Product as described in §2.3

This classification is valid for the following end use applications:

Substrate Steel sheet, thickness approx. 1.2 mm

(class A1/A2 according to EN 13238:2010)

Including 40 mm air gap Air gap

Methods and means of fixing Glued using the products adhesive

Joints Vertical only

Other aspects of end use

conditions

Used on various super wide format printers

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

Consult classification standard and national laws and regulations for limitations on the period of validity of the classification.

LIMITATIONS

This classification document does not represent type approval or certification of the product.

G. van der Lee M.Sc.

Junior project leader Reaction to Fire

A.H.L.M. Zwinkels B.Sc. Project leader Reaction to Fire

B.R. Knottnerus B.Sc. Project leader Reaction to Fire