



CERTIFICATE

CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw0554_2021

According to reports N° DO-20-2392\A-R2 and A20.07796.01, dated on 21/01/2021 and 17/12/2020, we confirm that the below mentioned item was tested at Centexbel with reference to EN-ISO 11952-2: Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test and at CREPIM with reference to EN 13823: Reaction to fire tests for building products. Building products excluding floorings exposed to the thermal attack by a single burning item.

The items shows

'EU fire classification C-s2,d0'

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2007 +A1:2009: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

**Collection
Company**

Squid Opaque® Chalk-Bone-Oak-Ash-Rock-Coal
Lampe_textiles
Kanegemstraat 28
8700 Tielt
Belgium

Certificate No. jw0554_2021 is valid until 20/01/2026

Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 26/02/2021

Inge De Witte, PhD
Certification Manager